



Certificate number: 2204703 (1)

Issued 01/04/2022

Expires 01/11/2026

Kiwa Regulation 4 (KUKreg4) Certification

Evaluation Guideline – Kiwa UK – EG004 – Regulation 4(1)(a)

Model number(s) – see Appendix

Dolphin Solutions Ltd

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied upon to comply with the Kiwa Evaluation Guideline referred above.

Which verifies the requirements of:

Regulation 4(1)a of the Water Supply (Water Fittings) Regulations 1999 England & Wales: 2009 Northern Ireland and 2014 Byelaws Scotland.

This certificate has been issued in accordance with the Kiwa regulations for product certification.

Signed on behalf of Kiwa Watertec

David Jay, Business Unit Manager – Authorised Signatory
Kiwa Watertec

Publication of this certificate is allowed.

Products are intended to be used in the UK only. For other countries, other (National) requirements will apply.

See <https://www.kiwa.com/gb/en/about-kiwa/water-products/> to ensure that the certificate is still valid.

CERTIFICATE

Kiwa Watertec
(A Trading Division of Kiwa Ltd)
26A Rassau Industrial Estate
Ebbw Vale
Gwent
NP23 5SD
United Kingdom
T +44 (0)1495 308185
uk.water@kiwa.com
www.kiwa.co.uk

Certificate Issued to:

Compass Park
Southpoint
Junction Rd
Bodiam
Robertsbridge
TN32 5BS



Product Certificate

Appendix to Certificate number: 2204703

The following products belong to this certificate

<p>PRODUCT DESCRIPTION Range of concealed WC flushing cisterns incorporating a side entry compact type float operated inlet valve providing a Type AG air gap with a dual flush drop valve for full flush volumes of up to 6 litres and a reduced flush of up to 4 litres. The cistern is operated by a manual push button and incorporates a servicing valve and flexible hose on the inlet supply ATS3 – Without Production Surveillance.</p>
<p>MODEL(S) DB551x.M DB551x.P where x can be replaced by a number from 0 - 9 to indicate the type of mounting or frame supplied attached to the cistern.</p>
<p>SIZE: ½" BSP (M).</p>
<p>SCOPE: Manufacturer recommended maximum working pressure 10 Bar & maximum operating temperature: Cold Water use only. Hygienic Purposes: Non-metallic materials suitable for continuous use with cold water only. Above ground use only.</p>
<p>MARKING Adhesive label within cistern opposite access opening and adjacent to water point entry: Dolphin, Dolphin logo, 126, product date DD/MM/YY within cistern.</p>
<p>MATERIALS Non-metallic materials assessed (BS6920) to backflow prevention device.</p>
<p>BACKFLOW PROTECTION NOTES N/a</p>
<p>ADDITIONAL NOTES All water contact & exposed components satisfy opacity requirements</p> <p>Suitable for use in a WC suite, provided it forms an arrangement which meets the requirements of Type AUK1 and an appropriate WC performance specification. Please refer to the clarification of the requirements of the Water Supply(Water Fittings) Regulations, Byelaws in Scotland, as they apply to Type AUK1 air gaps in WC suites.</p>

Extra Notes