

# Directory Search Results

---

WRAS Approval Number: 2003902

Approved Product

Range of wall mounted bib taps (chromium plated brass), incorporating quarter turn ceramic disc headworks with single lever operating members. The spout outlets incorporate plastic flow straightener. Maximum working pressure 7.0 bar. Maximum operating temperature 60°C.

- **Section:** 1750 Taps (?section=1750)
- **Section Subtitle:** Draw off, metal, bib. a. All cold water fittings located outside the thermal envelope, or those outside the building should be protected against damage by freezing. b. A servicing valve shall be fitted to the supply pipe to this fitting and shall be located within the thermal envelope of the building.
- **WRAS Approval Number:** 2003902
- **Expiry date:** 31/03/2025
- **Size:** ½" BSP (M)
- **Marking:** Bristan on operating members
- **Installation Requirements** R001 (/approvals/testing-requirements/installation\_requirements/irn\_r001)R040 (/approvals/testing-requirements/installation\_requirements/irn\_r040)
- **Model**  
VAL BIB C CD  
VAL BIB C 6 CD

Models added January 2021: VAL2 BIB C CD & VAL2 BIB C 6 CD

- **Factor:** Bristan Group Ltd. [View All Listings by this Company \(?company=16326\)](#)